



CITY OF SAN AUGUSTINE

301 SOUTH HARRISON
SAN AUGUSTINE, TX 75972
TEL: (936) 275.2121
FAX: (936) 275.9146

TO: Citizens of San Augustine

May 28, 2019

SUBJECT: Publication of Calendar Year 2018 Water Quality Report

Dear Citizens:

The Environmental Protection Agency (EPA) and the Texas Commission on Environmental Quality (TCEQ) require annual reports regarding the public water supply furnished by the City of San Augustine. I have attached the report and data sheet to this letter.

Our drinking water is regulated by the Texas Commission on Environment Quality (TCEQ) and they have determined that our water has had no issues' that prevents it from meeting or exceeding water quality standards and requirements as stated in the Federal Drinking Water Standards.

We are having an open meeting concerning our water quality report on MONDAY, July 8, 2019 at 10:00 A.M. at City Hall, 301 South Harrison. Please come join us if you have questions.

Thank you for your interest.

Chris Anding
Superintendent

ATTACHMENT a/s

2018 DRINKING WATER QUALITY REPORT CITY OF SAN AUGUSTINE AND RURAL WATER CUSTOMERS

Phone No. 936-275-2121

CONSUMER CONFIDENCE REPORT 2018

OUR DRINKING WATER IS REGULATED

By the Texas Commission on Environmental Quality (TCEQ) and they have determined that certain water quality issues exist. The City of San Augustine has met all of the requirements as stated in the Federal Drinking water standards.

This report is a summary of the quality of the water we provide to our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

En Espanol

Este informe incluye informacion importante sobre el agua potable. Si tiene preguntas o comentarios sobre este informe en espanol, favor de llamar al tel. (936) 275-2121.

Our drinking water is obtained from SURFACE water sources. It comes from Lake / River / Reservoir / Aquifer: San Augustine City Lake.

WATER SOURCES: The sources of drinking water (both tap and bottled) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment includes: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants.

SPECIAL NOTICE for ELDERLY, INFANTS, CANCER PATIENTS, people with HIV / AIDS or other immune problems:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV / AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health providers. EPA / Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water HOTLINE (800-426-4791).

ALL drinking water may contain contaminates:

When drinking water meets federal standards there may not be any health-based benefits to purchasing bottled water or point of service devices. Drinking water, including bottled water, may reasonably be expected to contain a least small amounts of some contaminates. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling EPA Safe Drinking Water HOTLINE (800-426-4791).

Secondary Constituents

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, odor, and color problems. The taste and color constitutes are called secondary constituents and are regulated by State of Texas, not EPA. **These constituents are not causes for health concerns.** Therefore, secondaries are not required to be reported in this document but may greatly affect the appearance and taste of your water.

About The Following Pages

The pages attached and below listed definitions provide all of the federally regulated or monitored constituents which have been found in your drinking water. U.S. EPA requires water systems to test up to 97 contaminants. The tables below contain all of the chemical constituents, which have been found in your drinking water. The City of San Augustine tested our water quality over 2,400 times in calendar year 2018.

DEFINITIONS

Maximum Contaminant Level (MCL) – The highest level of contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) – The level of a contaminant in drinking water below which there is not known or expected health risk. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.

Action Level (AL) – The concentration of a contaminant, which, if exceeded, triggers treatment, or other requirements, which a water system must follow.

ABBREVIATIONS

NTU - Nephelometric Turbidity Units – Turbidity is the amount of particles in the water. **Our source is from soil (Red Dirt) runoff into the City Lake.**

MFL – million fibers per liter (a measure of asbestos)

pCi/l – picocuries per liter (a measure of radioactivity)

ppm – parts per million, or milligrams per liter (mg/l)

ppb – parts per billion, or micrograms per liter (ug/l)

ppt – parts per trillion, or nanograms per liter

ppq – part per quadrillion, or picograms per liter

Public Participation Opportunities:

DATE: July, 8 2019

TIME: 10:00 A.M.

LOCATION: City Hall Council Chambers

PHONE: 936-275-2121

Chris Anding
Superintendent

Turbidity

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

Year	Contaminant	Highest Single Measurement	Lowest Monthly % of Samples Meeting Limits	Turbidity	Unit of Limits	Source of Contaminant
2018	Turbidity	0.89	97.00%	0.3	NTU	Soil Runoff

Organic Contaminants

Tested In 2018

Cryptosporidium Monitoring Information

"We monitored for *Cryptosporidium*, a microbial parasite that may be commonly found in surface water. *Cryptosporidium* may come from animal and human feces in the watershed. The result of our monitoring indicated that there may be *Cryptosporidium* in the raw water and/or treated finished water. Although treatment by filtration removes *Cryptosporidium*, it cannot guarantee 100 percent removal. The testing methods used cannot determine if the organisms are alive and capable of causing cryptosporidiosis, an abdominal infection with nausea, diarrhea and abdominal cramps that may occur after ingestion of contaminated water."

Total Coliform NOT DETECTED

Fecal Coliform NOT DETECTED

Disinfection Byproducts

Year	Contaminant	Average Level Measurement	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2018	Total Haloacetic Acids	60	38.7	78.8	60	ppb	Byproducts of Drinking Water
2018	Total Trihalomethanes	91	64.3	110	80	ppb	Disinfection

Unregulated Initial Distribution System Evaluation for Disinfection Byproducts

This evaluation is sampling required by EPA to determine the range of total trihalomethane and haloacetic acid in the system for nature regulations. The samples are not used for compliance, and may have been collected under non-standard conditions. EPA also requires the data to be reported here.

Year	Contaminant	Average Level Measurement	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2018	Total Haloacetic Acids	60	38.7	78.8	60	ppb	Byproducts of Drinking Water
2018	Total Trihalomethanes	91	64.3	110	80	ppb	Disinfection

Inorganic Contaminates

Year	Contaminant	Average Level Measurement	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Source of Contaminant
2018	Gross Alpha	1.2	1.2	1.2	1.5	0	pCi/L	Erosion of Natural Deposits
2018	Barium	0.017	0.017	0.017	2	2	ppm	discharge of drilling waste,
2018	Chromium	0.001	0.001	0.001	0.1	0.1	ppb	discharge from steel mills
2018	Nitrate (measured as Nitrogen)	0.0984	0.0984	0.0984	10	10	ppm	runoff from fertilizer use.
2018	Fluoride	0.0324	0.0324	0.0324	4	4	ppm	Erosion of Natural Deposits; Runoff from fertilizer use.

Maximum Residual Disinfection Level

Systems must complete and submit disinfection data on the Surface Water Monthly Operating Report (SWMOR). On the CCR report, the system must provide disinfection type. Minimum, maximum, and average levels.

Year	Disinfectant Used	Average Level Quarterly Avg.	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Source of Contaminant
2018	Chlorine	1.67	1.06	2.7	4.0	<4.0	ppm	Chlorine Gas

Unregulated Initial Distribution System Evaluation for Disinfective Byproducts WAIVED OR NOT YET SAMPLED

Total Organic Carbon (TOC)

Total Organic Carbon (TOC) no health effects. The disinfectant can combine with TOC to form disinfectant byproducts. Disinfection is necessary to ensure that water does not have unacceptable levels of pathogens. Byproducts of disinfection include Trihalomethanes (THM's) and Haloacetic Acids (HAA) which are reported elsewhere in this report.

Year	Contaminant	Average Level Measurement	Minimum Level	Maximum Level	Unit of Measure	Source of Contaminant
2018	Lake Water	9.21	2.00	78.80	ppm	Naturally Present in Lake
2018	Drinking Water	2.42	1.40	7.10	ppm	Naturally Present in Lake
2018	Removal Ratio	1	1	1		

We used alternative calculations
Removal Ratio is the percent of TOC removed by the treatment process divided by the percent of TOC required by TCEQ to be removed.

Unregulated Contaminants

Bromoform, Chloroform, dichlorobromomethane, and dibromochloromethane are disinfectant byproducts. There is no maximum contaminant level for these chemicals at the entry point to distribution.

Year or Range	Contaminant	Average Level	Minimum Level	Maximum Level	Unit of Measurement	Source of Contaminant
2018	Bromodichloromethane	13.5	10	17.2	ppb	Byproduct of drinking water disinfection
2018	Dibromochloromethane	2.35	1.27	3.27	ppb	Byproduct of drinking water disinfection
2018	Chloroform	62.8	92	52	ppb	Byproduct of drinking water disinfection

2018 Water Loss

2018	Produced Water	Total Water Loss Volume	Total Water Loss %
2018	260,643,000	22,813,882	12.23%

VIOLATIONS

VIOLATION TYPE	Health Effects	Duration	Explanation	Steps to Correct
DISTRIBUTION: MCL VIOLATION - TOTAL TRIHALOMETHANES	Some people who drink water containing trihalomethanes in excess of the MCL OVER MANY YEARS may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer. Proper notices have been made	1/1/2018 to 12/31/2018	water samples showed that the amount of this contaminant in our drinking water was above its MCL for the period indicated	We now have the new storage tanks on line and our water quality has improved, The running annual average for the first quarter of 2019 is 0.078 The MCL for TTHM is 0.080.

Violations

Public Notice Rule	Violation Begin	Violation End	Explanation	Steps to Correct
Linked To Violation	2/21/2014	6/11/2018	We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.	The City now has a web page, Customers can go to this page and view all public notices.
Linked To Violation	5/14/2018	12/6/2018		
Linked To Violation	7/7/2018	12/6/2018		
Linked To Violation	10/9/2018	12/6/2018		